

Warden Intercom Point (WIP) Phone

 **NOTIFIER**[®]
by Honeywell

Evacuation

General

Warden Intercom Point (WIP) phones are designed for communication between the Floor Wardens and the Emergency Warning and Intercommunication System panel.

When taken from the cradle the WIP automatically rings the EWIS panel. When the EWIS panel calls the WIP phone, the call tone sounds from the speaker in the body.

When the handset is lifted, it automatically switches from the speaker in the body to the speaker in the handset and a communication link is made to the EWIS panel.

Features

- Separate speaker for call tone
- Simple two wire connection
- Includes wall mounting bracket
- Compatible with all I2000 systems

Approvals

The Notifier WIP phone has been certified as complying with AS/ACIF S004.

It has been tested as a WIP phone for intercommunication system for emergency purposes to AS2220.1 at both the C.I.E. and the WIP locations if installed to AS 1670.4 .



Specifications:

Operating Voltage (Current):	6VDC (at 9mA) to 15VDC (at 22.5mA)
AC Impedance:	600 ohms off-hook 25 - 50 ohms on-hook
Ring Voltage:	6VAC r.m.s.
Ring SPL:	Approximately 82dBA @ 1m
Ambient Temperature:	-10°C to +50°C
Terminals:	Screw, to fit 0.75mm ² to 1.5mm ² wire
Material:	Impact resistant ABS
Colour:	Red

© 2009 by Honeywell International Inc. All rights reserved.
Unauthorised use of this document is strictly prohibited.

This document is not intended for installation purposes.
We try to keep our product information up-to-date and accurate.
We cannot cover all specific applications or anticipate all requirements.
All specifications are subject to change without notice.

For more information contact your nearest Notifier Sales Office or Distributor
www.notifier.com.au
