

Reference #: 14-012

Date: 12th Dec 2014

BacNet Gateway

NOTIFIER has released BacNet Gateway v3.24 firmware.

This update addresses an issue whereby Noti-Fire-Net performance may be unexpectedly slow during a de-isolate event from an AFP-2800 Fire Alarm Control Panel.

It is recommended that all BacNet gateways installed on AFP-2800 networks use v3.24 for best system performance.

Compatibility:

The minimum software versions required for the network interface cards on a NOTI-FIRE-NET is NCM-W/F Version 3.060.006

Please contact your NOTIFIER technical support with any technical questions.