

Date: 24th September, 2007

Affected Products: AZM-8 distributed modules
Noti-Fire-Network
Notifier integration products ie.

- OnyxWorks
- BacNet Gateway
- Onyx FirstVision

Onyx FirstVision does not currently support the use of AZM-8 distributed ring modules.

Although AZM-8 modules are supported on the Noti-Fire network and current releases of OnyxWorks, to help maintain the compatibility of sites with future network product releases it is not recommended to include AZM-8 modules into the design of such network systems.

In situations where distributed IO is required on network systems it is suggested to utilize addressable loop modules such as XP-6C/MA/R and XP-10M in place of AZM-8 modules.

If you have any question please do not hesitate to contact me.

Sincerely,



James Edwards
Product Manager