


Date: 14th, April 2008

Affected Products: AFP-2800 PC Interface v5.03

A minor issue has been identified with v5.03 AFP-2800 PC Interface where a 'subscript out of range error' error is thrown when trying to print a panel configuration to a text file. As an interim workaround unselect the 'Global Options' checkbox as shown below.



If you have any question please do not hesitate to contact me.

Sincerely,

James Edwards
Product Manager